

ENVI ECOTECH SERVICES PVT. LTD. (Analytical Laboratory Division)

ISO/IEC - 17025 : 2017 Accredited Testing Laboratory by NABL Vide Certificate Number TC - 5951.

Plot No. 99, Gali No. 04, Navlu Colony, Railway Station Road, Ballabgarh - 121004, Faridabad (Haryana) Phone No.:+91-129-4630926, M.: 9650160159, 9911378912

E-mail: ecofbd@yahoo.com, info@ecotechservices.in

Website: www.ecotechservices.in MSME No.: UDYAM-HR-03-0076916 CIN NO: U71200HR2023PTC116170

TEST REPORT

Test Report Issued To:-		ULR Number TC-5951-25000000256%			
M/s Delhi Public School Ballabgarh- Faridabad Haryana.		Date of Report	05/03/2025 EES/2024-2025/0936 04/03/2025 to 05/03/2025 Drinking Water Sample.		
		Work Order No.			
		Period of testing			
		Type of Sample			
		Date of Receiving	04/03/2025		
		Sampling Methods	N/A		
		Sample received by	Mr. Basant Kumar		
Description of Sample.	One "Drinking Water" sample was received by Envi Ecotech Laboratory Representative Mr. Basant Kumar on 04/03/2025.				
Sample Code / Locations.	Sample Marked as "R.O. Drinking Water Sample"				

Test Results.

S. No.	Test Parameter's.	Units	Test Results	Limits as per IS :10500:2012 (Reaffirmed 2018) Requirement (Acceptable) Limit)	Method of Test, Ref. to Part of IS: 3025.
Table-1,	2- Organoleptic, Physica	al and Genera	l Parameters of D	rinking Water. :- (Clause -4.0)	
1	Colour	CU	<1.0	5max.	IS: 3025(P- 04)
2	Odour	Agreeable	Agreeable	Agreeable	IS: 3025(P-05)
3	Turbidity	NTU	< 0.02	1.0max.	IS: 3025(P- 10)
4	pH value at 25 Deg. C	<i>,</i> - 1	6.83	6.5-8.5	IS: 3025(P-11)
5	TDS	mg/L	49	500max.	IS: 3025(P- 16)
6	Total Hardness	mg/L	4.0	200max.	IS: 3025(P-21)
7	Total Alkalinity	mg/L	22	200max.	IS: 3025(P-23)
8	Chloride as Cl	mg/L	29	250max.	IS: 3025(P- 32)
9	Iron as Fe	mg/L	BDL(<0.075)	0.3max.	IS: 3025(P- 53)
10	Fluoride as F	mg/L	BDL(<0.05)	1.0max.	IS: 3025(P- 60)
11	Calcium as Ca	mg/L	1.5	75max.	IS: 3025(P- 40)
12	Magnesium as Mg	mg/L	1.0	30max.	IS: 3025(P- 46)
13	Sulphate as SO4	mg/L	BDL(<1.0)	200max.	IS: 3025(P- 24)

BDL= Below Detectable Limits. | Remarks: - The above tested parameters are under the Acceptable Limit as per IS: 10500:2012 (Reaff.2018). Conditions:-

The above mentioned results relates to the tests specified by the customer for the given sample.

The test report shall not be reproduced except in full, without the written approval of the Laboratory.

This test report shall not be used in any advertising media or as evidence in the Court of Low without prior written consent of Laboratory.

The test sample will be disposed off after two weeks from the date of issue of report.

----End of report----

Mr. R. Chauhan (General Manager - Q & T.)